

Statistics					
	Average	Maximum	Minimum	Max/Min	Avg/Min
SOCCER	30.7	36.8	21.5	1.7	1.4



These lighting calculations are not a substitute for an independent engineering analysis of lighting system suitability and safety.

Luminaire Schedule				
Symbol	Qty	Catalog No.	Lamp	Initial Lumens
N	28	ASPX5M GN	MH1500/BU-HOR	151900
M	8	ASPX5M GM	MH1500/BU-HOR	151900

Notes	
1)	Levels shown are maintained horizontal illuminance.
2)	Based on a light loss factor of .80
3)	Results are shown in units of footcandles.
4)	Levels shown are taken 3 Feet above grade.
5)	Includes effects of lamp operating position.
6)	EPA does not include bracketry
7)	Levels based on rated input voltage supplied to ballast

Luminaire Legend				
Pole	Quantity	EPA[FT SQ]	Power[KVA]	Height
A1	9	29.7	14.49	80
A2	9	29.7	14.49	80
A3	9	29.7	14.49	80
A4	9	29.7	14.49	80

Drawing Number:	Drawn By:
SCB431AS	Approved:
Sheet 1 of 1	Date: 10/13/03
	Scale: 1 Inch = 100 Feet

TYPICAL 180 X 300 SOCCER FIELD